

# City of Austin Water Quality Laboratory

## Drinking Water Quality Report

Samples Collected Between 11/01/2022 - 11/30/2022

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP	
pH	SU	Avg	9.6	Avg	9.6	Avg	9.6	
		Max	9.7	Max	9.7	Max	9.7	
		Min	9.6	Min	9.5	Min	9.6	
Total Alkalinity	mg/L as CaCO3	Avg	68	Avg	70	Avg	79	
		Max	72	Max	74	Max	89	
		Min	62	Min	65	Min	74	
Total Hardness	mg/L as CaCO3	Avg	98	Avg	100	Avg	104	
		Max	103	Max	104	Max	112	
		Min	91	Min	96	Min	99	
Total Solids	mg/L	Avg	221	Avg	247	Avg	214	
		Max	240	Max	270	Max	240	
		Min	198	Min	230	Min	194	
Total Chloramines	mg/L	Avg	2.80	Avg	2.66	Avg	2.75	
		Max	3.00	Max	2.85	Max	2.90	
		Min	2.60	Min	2.50	Min	2.55	
Total Organic Carbon	mg/L	Avg	2.75	Avg	2.64	Avg	2.61	
		Max	2.87	Max	2.78	Max	2.74	
		Min	2.60	Min	2.56	Min	2.48	
Conductivity	umhos/cm	Avg	334	Avg	339	Avg	379	
		Max	336	Max	343	Max	380	
		Min	332	Min	335	Min	377	
Turbidity	NTU	Avg	.07	Avg	.04	Avg	.04	
		Max	.08	Max	.07	Max	.06	
		Min	.05	Min	.03	Min	.03	