

**City of Austin Water Quality Laboratory**  
**Drinking Water Quality Report**

Samples Collected Between 07/01/2021 and 07/31/2021

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP
pH	SU	<b>Avg</b>	9.8	<b>Avg</b>	9.7	<b>Avg</b>	9.6
		<b>Max</b>	9.9	<b>Max</b>	9.8	<b>Max</b>	9.6
		<b>Min</b>	9.7	<b>Min</b>	9.6	<b>Min</b>	9.5
Total Alkalinity	mg/L as CaCO3	<b>Avg</b>	49	<b>Avg</b>	54	<b>Avg</b>	71
		<b>Max</b>	54	<b>Max</b>	60	<b>Max</b>	78
		<b>Min</b>	47	<b>Min</b>	51	<b>Min</b>	69
Total Hardness	mg/L as CaCO3	<b>Avg</b>	81	<b>Avg</b>	90	<b>Avg</b>	95
		<b>Max</b>	84	<b>Max</b>	94	<b>Max</b>	103
		<b>Min</b>	78	<b>Min</b>	86	<b>Min</b>	93
Total Solids	mg/L	<b>Avg</b>	165	<b>Avg</b>	181	<b>Avg</b>	189
		<b>Max</b>	212	<b>Max</b>	220	<b>Max</b>	208
		<b>Min</b>	124	<b>Min</b>	138	<b>Min</b>	160
Total Chloramines	mg/L	<b>Avg</b>	2.84	<b>Avg</b>	2.73	<b>Avg</b>	2.84
		<b>Max</b>	3.05	<b>Max</b>	2.90	<b>Max</b>	2.92
		<b>Min</b>	2.75	<b>Min</b>	2.50	<b>Min</b>	2.70
Total Organic Carbon	mg/L	<b>Avg</b>	2.34	<b>Avg</b>	2.31	<b>Avg</b>	2.25
		<b>Max</b>	2.43	<b>Max</b>	2.35	<b>Max</b>	2.28
		<b>Min</b>	2.25	<b>Min</b>	2.29	<b>Min</b>	2.20
Total Trihalomethanes	ug/L	<b>Avg</b>	32.9	<b>Avg</b>	31.7	<b>Avg</b>	22.0
		<b>Max</b>	34.4	<b>Max</b>	31.7	<b>Max</b>	22.0
		<b>Min</b>	31.3	<b>Min</b>	31.7	<b>Min</b>	22.0
Turbidity	NTU	<b>Avg</b>	0.06	<b>Avg</b>	0.03	<b>Avg</b>	0.02
		<b>Max</b>	0.07	<b>Max</b>	0.07	<b>Max</b>	0.08
		<b>Min</b>	0.05	<b>Min</b>	0.02	<b>Min</b>	0.02

Due to Covid-19 the number of parameters analyzed has been reduced effective 03/27/2020.